



Business Services

Contracts Office

5735 47th Avenue • Sacramento, CA 95824

(916) 643-2464

Rose Ramos, Chief Business Officer

Jessica Sulli, Contract Specialist

ADDENDUM NO. 1

Date: September 21, 2020

Issued by: Sacramento City Unified School District

Project: H.W. Harkness Outdoor Learning Space Phase 3

You are hereby notified of the following changes, clarifications, or modifications to the original Contract Documents, Specifications, and Drawings. This Addendum shall supersede the original project documents, and shall take precedence over anything to the contrary therein. All Addenda shall be acknowledged in the Bid Form. Failure to do so may result in disqualification of the bid. All other conditions remain unchanged.

RESPONSE TO REQUEST FOR CLARIFICATION

Question: The interlocking concrete pavers per plans come in three different heights. This information is not found on the plans or within the specifications. Please specify 60mm, 80mm or 100mm height.

Response: The product with 60mm thickness will be appropriate for the application.

END OF ADDENDUM NO. 1