


Camellia Basic Elementary School (035)
6600 Cougar Drive
SACRAMENTO CITY UNIFIED SCHOOL DISTRICT

AHERA Management Plan

CAMELLIA



DRAWING No.	2
SPACE	ATTIC & CRAWL
FLOOR	1ST

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 035 **CAMELLIA** **Address: 6600 COUGAR DRIVE, Sacramento 95828**

Building No: 00A **Room** **C003** **Description** **Office** **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound

Building No: 00A **Room** **O003** **Description** **Classroom** **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Lay In	M	N	960 SF	Non ASB	Sampled	0	B1100	
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343	Installed during HVAC renovation.
Flooring	Tile 12 In.	M	N	960 SF	Non ASB	Sampled	0	D2074	
Piping	Heat Hot Water Insulation	T	N	40 LF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound
Wall	Transite Chalk Board	M	N	64 SF	Other	Assumed	N/A		Behind newer board

Building No: 00A **Room** **O004** **Description** **Classroom** **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Lay In	M	N	960 SF	Non ASB	Sampled	0	011B00	
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343	Installed during HVAC renovation.
Flooring	Tile 12 In.	M	N	960 SF	Non ASB	Sampled	0	D2074	
Piping	Heat Hot Water Insulation	T	N	32 LF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound
Wall	Transite Chalk Board	M	N	64 SF	Other	Assumed	N/A		Behind newer board

Building No: 00A **Room** **O005** **Description** **Classroom** **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Lay In	M	N	960 SF	Non ASB	Sampled	0	B1100	
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343	Installed during HVAC renovation.
Flooring	Tile 12 In.	M	N	960 SF	Non ASB	Sampled	0	D2074	Under newer flooring
Piping	Heat Hot Water Insulation	T	N	32 LF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound
Wall	Transite Chalk Board	M	N	64 SF	Other	Assumed	N/A		Behind newer board

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 2 of 17

SITE: 035 CAMELLIA Address: 6600 COUGAR DRIVE, Sacramento 95828

Building No: 00A Room O006 Description Classroom Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Lay In	M	N	0 SF	Non ASB	Sampled	0	011B00	
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343	Installed during HVAC renovation.
Flooring	Tile 12 In.	M	N	960 SF	Non ASB	Sampled	0	D2074	
Piping	Heat Hot Water Insulation	T	N	32 LF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound
Wall	Transite Chalk Board	M	N	64 SF	Other	Assumed	N/A		Behind newer board

Building No: 00A Room O007 Description Classroom Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	960 SF	Non ASB	Sampled	0	D2080	
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343	Installed during HVAC renovation.
Flooring	Tile 12 In.	M	N	960 SF	Non ASB	Sampled	0	D2074	
Piping	Heat Hot Water Insulation	T	N	32 LF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound

Building No: 00A Room O009 Description Classroom Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Lay In	M	N	960 SF	Non ASB	Sampled	0	B1100	
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343	Installed during HVAC renovation.
Flooring	Tile 12 In.	M	N	960 SF	Non ASB	Sampled	0	D2074	
Piping	Heat Hot Water Insulation	T	N	32 LF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound

Building No: 00A Room O010 Description Classroom Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	960 SF	Non ASB	Sampled	0	D2080	
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343	Installed during HVAC renovation.
Flooring	Tile 12 In.	M	N	960 SF	Non ASB	Sampled	0	D2074	Under newer flooring
Piping	Heat Hot Water Insulation	T	N	32 LF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 3 of 17

SITE: 035		CAMELLIA			Address: 6600 COUGAR DRIVE, Sacramento 95828			
Building No:	00A	Room	0011	Description	Classroom	Drawing No:	1	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Tile, Splined	M	N	960 SF	Non ASB	Sampled	0	D2080
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343 Installed during HVAC renovation.
Flooring	Tile 12 In.	M	N	960 SF	Non ASB	Sampled	0	D2074
Piping	Heat Hot Water Insulation	T	N	32 LF	Other	Assumed	N/A	
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093 Asb. in taping compound
Wall	Transite Chalk Board	M	N	64 SF	Other	Assumed	N/A	

Building No:	00A	Room	0012	Description	Classroom	Drawing No:	1	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Tile, Lay In	m	N	SF	Non ASB	Sampled	0	B1100
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343 Installed during HVAC renovation.
Flooring	Tile 12 In.	M	N	960 SF	Non ASB	Sampled	0	D7074 Under newer flooring
Piping	Heat Hot Water Insulation	T	N	32 LF	Other	Assumed	N/A	
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093 Asb. in taping compound

Building No:	00A	Room	S001	Description	Storage	Drawing No:	1	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093 Asb. in taping compound
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093 Asb. in taping compound

Building No:	00A	Room	S002	Description	Storage	Drawing No:	1	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093 Asb. in taping compound
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093 Asb. in taping compound

Building No:	00A	Room	T03A	Description	Toilet	Drawing No:	1	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Tile, Splined	M	N	200 SF	Non ASB	Sampled	0	D2080
Flooring	Vinyl Sheet	M	N	200 SF	Serp	Sampled	15	B3444
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093 Asb. in taping compound

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 4 of 17

SITE: 035 CAMELLIA Address: 6600 COUGAR DRIVE, Sacramento 95828

Building No: 00A Room T03B Description Toilet Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	200 SF	Non ASB	Sampled	0	D2080	
Flooring	Vinyl Sheet	M	N	200 SF	Serp	Sampled	15	B3448	
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound

Building No: 00A Room X008 Description Classroom Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	960 SF	Non ASB	Sampled	0	D2080	
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343	Installed during HVAC renovation.
Flooring	Tile 12 In.	M	N	960 SF	Non ASB	Sampled	0	D2074	Under newer flooring
Piping	Heat Hot Water Insulation	T	N	40 LF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 5 of 17

SITE: 035 CAMELLIA Address: 6600 COUGAR DRIVE, Sacramento 95828

Building No: 00B Room M001 Description Mechanical Room Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound

Building No: 00B Room S005 Description Storage Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound

Building No: 00B Room T002 Description Toilet Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound
Wall	Sheet Rock	M	N	SF	Serp	Sampled	1	B1091	Asb. In taping compound

Building No: 00B Room T003 Description Toilet Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound
Wall	Sheet Rock	M	N	SF	Serp	Sampled	1	B1091	Asb. In taping compound

Building No: 00B Room T004 Description Toilet Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound

Building No: 00B Room T006 Description Toilet Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound
Wall	Sheet Rock	m	N	SF	Serp	Sampled	1	B1091	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 6 of 17

SITE: 035		CAMELLIA				Address: 6600 COUGAR DRIVE, Sacramento 95828					
Building No:	00B	Room	T007	Description	Toilet		Drawing No:	1			
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #			
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1093	Asb. in taping compound		
Wall	Sheet Rock	M	N	SF	Serp	Sampled	1	B1091	Asb. in taping compound		

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 7 of 17

SITE: 035		CAMELLIA			Address: 6600 COUGAR DRIVE, Sacramento 95828				
Building No:	00C	Room	C01B	Description	Office		Drawing No:	1	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Mastic	M	N	SF	Non ASB	Sampled	0	B1622	
Ceiling	Acoustical Tile, Splined	M	N	900 SF	Non ASB	Sampled	0	D2077	
Ceiling	Sheet Rock	M	N	900 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Flooring	Mastic	M	N	SF	Serp	Sampled	5	J1183	Under newer flooring
Flooring	Tile 12 In.	M	N	SF	Non ASB	Sampled	0	J1427	
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1301	Asb. in taping compound

Building No:	00C	Room	C01C	Description	Office		Drawing No:	1	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	270 SF	Non ASB	Sampled	0	D2077	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Flooring	Mastic	M	N	270 SF	Serp	Sampled	5	J1183	Under newer flooring
Flooring	Tile 12 In.	M	N	SF	Non ASB	Sampled	0	J1427	
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

Building No:	00C	Room	C01F	Description	Office		Drawing No:	1	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Mastic	M	N	SF	Non ASB	Sampled	0	B1622	
Ceiling	Acoustical Tile, Splined	M	N	150 SF	Non ASB	Sampled	0	D2077	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Flooring	Mastic	M	N	150 SF	Serp	Sampled	5	J1183	Under newer flooring
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

Building No:	00C	Room	D005	Description	Dining Room		Drawing No:	1	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343	Installed during HVAC renovation.
Flooring	Tile 12 In.	M	N	512 SF	Non ASB	Sampled	0	D2075	
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 8 of 17

SITE: 035 CAMELLIA Address: 6600 COUGAR DRIVE, Sacramento 95828

Building No: 00C Room H002 Description Hallway/Stairs Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Mastic	M	N	SF	Non ASB	Sampled	0	B1632	
Ceiling	Acoustical Tile, Splined	M	N	1400 SF	Non ASB	Sampled	0	D2077	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Flooring	Tile 12 In.	M	N	SF	Non ASB	Sampled	0	J1427	Mastic Non-Detected asb

Building No: 00C Room H006 Description Hallway/Stairs Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Flooring	Tile 12 In.	M	N	100 SF	Non ASB	Sampled	0	D2075	
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

Building No: 00C Room J010 Description Custodial Closet Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

Building No: 00C Room J01J Description Custodial Closet Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Flooring	Tile 12 In.	m	N	SF	Non ASB	Sampled	0	B3345	
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

Building No: 00C Room K003 Description Kitchen Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Flooring	Tile 9 In. & Floor Mastic	M	N	400 SF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHRA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 9 of 17

SITE: 035 **CAMELLIA** **Address: 6600 COUGAR DRIVE, Sacramento 95828**

Building No: 00C **Room M013** **Description Mechanical Room** **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

Building No: 00C **Room M015** **Description Mechanical Room** **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1606	

Building No: 00C **Room M016** **Description Mechanical Room** **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

Building No: 00C **Room M01C** **Description Mechanical Room** **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	SF	Serp	Sampled	1	B1601	Asb. in taping compound
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

Building No: 00C **Room S004** **Description Storage** **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343	Installed during HVAC renovation.
Flooring	Tile 12 In.	M	N	250 SF	Non ASB	Sampled	0	D2075	
Wall	Fire Rated Door	M	N	21 SF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

Building No: 00C **Room S009** **Description Storage** **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 035		CAMELLIA				Address: 6600 COUGAR DRIVE, Sacramento 95828					
Building No:	00C	Room	S00Y	Description	Storage		Drawing No:	1			
Location	Homogeneous Material		Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock		M	N	0 SF		Serp	Sampled	1	B1601	Asb. in taping compound

Building No:	00C	Room	S012	Description	Storage		Drawing No:	1			
Location	Homogeneous Material		Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock		M	N	0 SF		Serp	Sampled	1	B1601	Asb. in taping compound
Flooring	Tile 9 In. & Floor Mastic		M	N	90 SF		Other	Assumed	N/A		
Wall	Sheet Rock		M	N	0 SF		Serp	Sampled	1	B1606	Asb. in taping compound

Building No:	00C	Room	S014	Description	Storage		Drawing No:	1			
Location	Homogeneous Material		Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock		M	N	0 SF		Serp	Sampled	1	B1601	Asb. in taping compound
Wall	Sheet Rock		M	N	0 SF		Serp	Sampled	1	B1601	Asb. in taping compound

Building No:	00C	Room	S01E	Description	Storage		Drawing No:	1			
Location	Homogeneous Material		Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock		M	N	30 SF		Serp	Sampled	1	B1601	Asb. in taping compound
Flooring	Mastic		M	N	130 SF		Serp	Sampled	5	J1183	Under newer flooring
Flooring	Tile 12 In.		M	N	SF		Non ASB	Sampled	0	J1427	
Wall	Sheet Rock		M	N	150 SF		Serp	Sampled	1	B1601	Asb. in taping compound

Building No:	00C	Room	S01H	Description	Storage		Drawing No:	1			
Location	Homogeneous Material		Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock		M	N	0 SF		Serp	Sampled	1	B1601	Asb. in taping compound
Flooring	Mastic		M	N	140 SF		Serp	Sampled	5	J1183	Under newer flooring
Flooring	Tile 12 In.		M	N	SF		Non ASB	Sampled	0	J1427	
Wall	Sheet Rock		M	N	0 SF		Serp	Sampled	1	B1601	Asbestos in taping compound

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 11 of 17

SITE: 035		CAMELLIA				Address: 6600 COUGAR DRIVE, Sacramento 95828					
Building No:	00C	Room	T007	Description		Toilet		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos		Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF		Serp		Sampled	1	B1601	Asb. in taping compound
Flooring	Tile 12 In.	M	N	SF		Non ASB		Sampled	0	J1427	Mastic Non-Detected asb
Wall	Sheet Rock	M	N	0 SF		Serp		Sampled	1	B1601	Asb. in taping compound

Building No:	00C	Room	T008	Description		Toilet		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos		Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF		Serp		Sampled	1	B1601	Asbestos in taping compound
Flooring	Tile 12 In.	M	N	SF		Non ASB		Sampled	0	J1427	Mastic Non-Detected asb
Wall	Sheet Rock	M	N	0 SF		Serp		Sampled	1	B1601	Asb. in taping compound

Building No:	00C	Room	T011	Description		Toilet		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos		Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF		Serp		Sampled	1	B1601	Asb. in taping compound
Flooring	Tile 9 In. & Floor Mastic	M	N	130 SF		Other		Assumed	N/A		
Wall	Sheet Rock	M	N	0 SF		Serp		Sampled	1	B1601	

Building No:	00C	Room	T01D	Description		Toilet		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos		Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF		Serp		Sampled	1	B1601	Asb. in taping compound
Flooring	Tile 12 In.	M	N	SF		Non ASB		Sampled	0	J1427	Mastic Non-Detected asb
Wall	Sheet Rock	M	N	0 SF		Serp		Sampled	1	B1601	Asb. in taping compound

Building No:	00C	Room	T0Y1	Description		Toilet		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos		Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	130 SF		Non ASB		Sampled	0	D2076	
Flooring	Vinyl Sheet	M	N	130 SF		Serp		Sampled	15	B3448	
Wall	Sheet Rock	M	N	0 SF		Serp		Sampled	0	B1601	Asb. in taping compound

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 12 of 17

SITE: 035 CAMELLIA Address: 6600 COUGAR DRIVE, Sacramento 95828

Building No: 00C Room TOY2 Description Toilet Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	130 SF	Non ASB	Sampled	0	D2076	
Flooring	Vinyl Sheet	M	N	130 SF	Serp	Sampled	15	B3448	
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	0	B1601	Asb. in taping compound

Building No: 00C Room U001 Description Multipurpose/Cafeteria Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Mastic	M	N	SF	Non ASB	Sampled	0	B1622	
Ceiling	Acoustical Tile, Splined	M	N	4000 SF	Non ASB	Sampled	0	D2077	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Flooring	Tile 12 In.	M	N	4000 SF	Non ASB	Sampled	0	D2075	
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

Building No: 00C Room U002 Description Multipurpose/Cafeteria Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound
Flooring	Tile 9 In. & Floor Mastic	M	N	800 SF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

Building No: 00C Room Y001 Description Kindergarten Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Lay In	M	N	SF	Non ASB	Sampled	0	B1622	
Ceiling	Acoustical Tile, Splined	M	N	1200 SF	Non ASB	Sampled	0	D2076	
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343	Installed during HVAC renovation.
Flooring	Mastic	M	N	SF	Serp	Sampled	5	J1183	
Flooring	Tile 9 In. & Floor Mastic	M	N	1200 SF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 13 of 17

SITE: 035		CAMELLIA				Address: 6600 COUGAR DRIVE, Sacramento 95828				
Building No:	00C	Room	Y002	Description	Kindergarten		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Acoustical Tile, Lay In	M	N	960 SF	Non ASB	Sampled	0	B1625		
Ceiling	Sheet Rock	m	N	SF	Non ASB	Sampled	0	B3343	Installed during HVAC renovation.	
Flooring	Tile 12 In.	M	N	1200 SF	Non ASB	Sampled	0	D2075		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound	

Building No:	00C	Room	Z011	Description	Misc. Room		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Acoustical Tile, Mastic	M	N	SF	Non ASB	Sampled	0	B1622		
Ceiling	Acoustical Tile, Splined	M	N	150 SF	Non ASB	Sampled	0	T1579		
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound	
Flooring	Mastic	M	N	150 SF	Serp	Sampled	5	J1183	Under newer flooring	
Flooring	Tile 12 In.	M	N	SF	Non ASB	Sampled	0	J1427		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound	

Building No:	00C	Room	Z01A	Description	Misc. Room		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Acoustical Tile, Splined	M	N	240 SF	Non ASB	Sampled	0	D2077		
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601	Asb. in taping compound	
Flooring	Mastic	M	N	SF	Serp	Sampled	5	J1183	Under newer flooring	
Flooring	Tile 12 In.	M	N	240 SF	Non ASB	Sampled	0	J1427		
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	1	B1601		

Building No:	00C	Room	ZA02	Description	Attic		Drawing No:	2		
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Wall	Sheet Rock	M	N	50 SF	Serp	Sampled	1	B1601	Asb. in taping compound	

Building No:	00C	Room	ZC01	Description	Crawl Space		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Piping	Heat Hot Water Insulation	T	Y	90 LF	Other	Assumed	N/A			

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 035		CAMELLIA				Address: 6600 COUGAR DRIVE, Sacramento 95828				
Building No:	00C	Room	ZEXT	Description	Exterior		Drawing No:	1		
Location		Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Exterior, Wall		Asbestos Cement Panel	M	N	2000 SF	Other	Assumed		N/A	

Building No:	P01	Room	O014	Description	Classroom		Drawing No:	1	Built With Non-Asbestos Materials	
Location		Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P02	Room	O013	Description	Classroom		Drawing No:	1	Built With Non-Asbestos Materials	
Location		Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P03	Room	T001	Description	Toilet		Drawing No:	1	Built With Non-Asbestos Materials	
Location		Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P03	Room	T002	Description	Toilet		Drawing No:	1	Built With Non-Asbestos Materials	
Location		Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P03	Room	T003	Description	Toilet		Drawing No:	1	Built With Non-Asbestos Materials	
Location		Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P03	Room	T004	Description	Toilet		Drawing No:	1	Built With Non-Asbestos Materials	
Location		Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 035		CAMELLIA			Address: 6600 COUGAR DRIVE, Sacramento 95828				
Building No:	P04	Room	O023	Description	Classroom	Drawing No:	1	Built With Non-Asbestos Materials	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P04	Room	O024	Description	Classroom	Drawing No:	1	Built With Non-Asbestos Materials	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P04	Room	O025	Description	Classroom	Drawing No:	1	Built With Non-Asbestos Materials	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 035		CAMELLIA			Address: 6600 COUGAR DRIVE, Sacramento 95828				
Building No:	P05	Room	O020	Description	Classroom	Drawing No:	1	Built With Non-Asbestos Materials	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P05	Room	O021	Description	Classroom	Drawing No:	1	Built With Non-Asbestos Materials	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P05	Room	O022	Description	Classroom	Drawing No:	1	Built With Non-Asbestos Materials	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P05	Room	O026	Description	Classroom	Drawing No:	1	Built With Non-Asbestos Materials	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P05	Room	O027	Description	Classroom	Drawing No:	1	Built With Non-Asbestos Materials	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 035		CAMELLIA			Address: 6600 COUGAR DRIVE, Sacramento 95828			
Building No:	P06	Room	O016	Description	Classroom	Drawing No:	1	Built With Non-Asbestos Materials
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #

Building No:	P06	Room	O017	Description	Classroom	Drawing No:	1	Built With Non-Asbestos Materials
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #

Building No:	P06	Room	O018	Description	Classroom	Drawing No:	1	Built With Non-Asbestos Materials
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #