



**Business Services**

**Contracts Office**

5735 47th Avenue • Sacramento, CA 95824

(916) 643-2464

*John Quinto, Chief Business Officer*

*Jessica Sulli, Contract Specialist*

**ADDENDUM NO. 2**

Date: March 7, 2019

Issued by: Sacramento City Unified School District

**Project: 0104-409, Elder Creek Roof Replacement**

You are hereby notified of the following changes, clarifications, or modifications to the original Contract Documents, Specifications, and Drawings. This Addendum shall supersede the original project documents, and shall take precedence over anything to the contrary therein. All Addenda shall be acknowledged in the Bid Form. Failure to do so may result in disqualification of the bid. All other conditions remain unchanged.

---

**CLARIFICATIONS**

1. Replace existing PVC condensate lines with new galvanized condensate lines. Set lines on rubber blocks installed 5' on center.
2. Remove antenna on MP roof.

**END OF ADDENDUM NO. 2**