



**Business Services
Contracts Office**

5735 47th Avenue • Sacramento, CA 95824
(916) 643-2464

*Rose Ramos, Chief Business Officer
Robert Aldama, Purchasing Manager II*

ADDENDUM NO. 1

Date: February 22, 2023
Issued by: Sacramento City Unified School District
**Project: Project #: 0040-461-2
Clayton B. Wire HVAC**

This addenda shall supersede the original Information, attachments, and specifications regarding Project No. **0040-461-2** where it adds to, deletes from, clarifies or otherwise modifies them. All other conditions and any previous addenda shall remain unchanged.

Part A – Bidding and Contract Requirements

AD1.01 REFER to Bidding Package

ALL certifications needed to submit with bid are enclosed in original Bid Package that was posted on SCUSD website and eBldr on February 3, 2023.

Part B- BIDDERS QUESTIONS

AD1.02 REFER TO FOLLOWING BIDDER’S RFIs:

Question #1: What does the District prefer: SEER 1 or SEER 2?

Response: Due to lead times and availability of items, District is fine with SEER 1.

Question #2: Will the existing flex connectors be used?

Response: Old ductwork shall be removed from connection before penetration through windows but not at flex connector. District does not want to reseal ductwork through wall. New flex connector installed with 4 inch filter rack on return.

Question #3: Are the units like-for-like replacement?

Response: Please refer to project scope- like for like replacement of 4 ton package units, new disconnects, phase 3 etc.

**Project No: 0040-461-2
Clayton B. Wire HVAC
ADDENDUM NO. 1**

Question #4: What does the District want to do with the existing equipment?

Response: Please dispose.

Question #5: Will a permit be required?

Response: No, this is a like-for-like maintenance project.

Question #6: Is there a certain equipment brand preferred?

Response: No, please do not specify brand in proposal unless the Contractor intends to use only the brand specified.

Question #7: Are economizers needed for each replacement unit?

Response: No, they are not needed. Fixed fresh air hood required.

END OF ADDENDUM NO. 1

Acknowledgement of this Addendum will be required at time of bid: