



**Business Services  
Contracts Office**

5735 47th Avenue • Sacramento, CA 95824  
(916) 643-2464

*Rose Ramos, Chief Business Officer  
Robert Aldama, Purchasing Manager II*

**ADDENDUM NO. 2.0**

Date: 07/17/2023

Issued by: Sacramento City Unified School District

**Project: Project #: 0510-464  
CK McClatchy HS Telecenter Upgrade Project**

This addendum shall supersede the original Information, attachments, and specifications regarding Project No. **0510-464** where it adds to, deletes from, clarifies or otherwise modifies them. All other conditions and any previous addenda shall remain unchanged.

---

**Part A – Bidding and Contract Requirements**

**AD 2.10:**

**Question:** Is the District willing to consider amending the plans and specifications with an addendum such that the network active components (Switches, UPS, licensing, etc.) will be OFCI (Owner Furnished, Contractor Installed)?

- a. These network-related active switch components and licenses represent a decent sized portion of these projects.
- b. These network-related active switch components and licenses are purchases the District already makes direct for similar projects.
- c. In most cases, these suppliers are the same ones the contractors will be using.
- d. The district can save additional markups by purchasing direct

**Answer:**

No, Contractor is able to purchase equipment listed.

Message obtained from CDWG regarding this:

*“In this circumstance I have the contractor order the HW/licenses under the districts account, then utilize a credit card or a form of Pre-payment. This way it meets the requirements of it being EDU, because it is on your account, then I work with the contractor to issue 1 of the 2 payments above directly to CDW”*

Other vendors available also

**Project No: 0510-464**  
**CK McClatchy HS Telecenter Upgrade Project**  
**ADDENDUM NO. 2**

**AD 2.13:**

**Question:** Is DVBE required for these projects? In bid documents, it states it is “encouraged” and “bidder may be asked to identify utilized DVBE”. Please clarify if required. If required please supply forms.

**Answer:** Please refer to bid documents. Bidder is encouraged to use DVBE when applicable.

**AD 2.14:**

**Question:** Please clarify when working hours can take place.

**Answer:** The work site is available during non-school hours. Work hours may be, for example, 4pm-12am M-F and most weekends.

**AD 2.15:** All exposed conduit observed on the job walk was EMT. Please confirm the conduit type requirements for all areas.

**Question:**

**Answer:** Typically we match whatever surface runway is available. If it's EMT then stay with that.

**AD 2.16:**

**Question:** The Iran Contra form is mentioned in bid documents but there is no form. Can you please supply?

**Answer:** This project does not have Iran Contracting Act certification requirements.

**AD 3.17:** Refer to DOCUMENT 00 11 16 **NOTICE TO BIDDERS**

**REVISE #6. /Notice To Bidders** as follows:

6. Electronic Bids will be received until 2:00 pm on July 20, 2023, after which time the bids will be opened and posted on eBuilder and SCUSD website.

**END OF ADDENDUM NO. 2.0**

**Acknowledgement of this Addendum will be required at time of bid.**