



**Business Services  
Contracts Office**  
5735 47th Avenue • Sacramento, CA 95824  
(916) 643-2464  
*Janea Marking, Chief Business Officer  
Robert Aldama, Purchasing Manager II*

**ADDENDUM NO. 2**

Date: February 27, 2025  
Issued by: Sacramento City Unified School District  
**Project: Project #: 25-032025  
Recoating Wood Floors at Various School Sites**

This addenda shall supersede the original Information, attachments, and specifications regarding Project No. 25-032025 where it adds to, deletes from, clarifies or otherwise modifies them. All other conditions and any previous addenda shall remain unchanged.

---

**Part A – Bidding and Contract Requirements**

**AD2.01 BIDDER QUESTIONS**

**QUESTION #1:**

Can we extend the project schedule to include an additional week, completing the week of August 4, 2025?

**ANSWER #1:**

No

**QUESTION #2**

Can we substitute the specification finish to an alternate which would be Gymshoe finish from Basic Coating? In our experience this option hold up better and longer than the specified finish.

**ANSWER #2:**

Substitute is not approved; does not meet solids content of product specified.

**QUESTION #3:**

The bid is currently calling to install just 1 coat, however, when we walked the spaces it appears they need to apply 2 coats. Would you like us to price an additional cost as an alternate?

**ANSWER #3:**

One coat only.

**END OF ADDENDUM NO. 2**

**Acknowledgement of this Addendum will be required at time of bid:**