

Business Services Contracts Office

5735 47th Avenue • Sacramento, CA 95824 (916) 643-2464

Gerardo Castillo, Chief Business Officer Kimberly Teague, Contract Specialist

ADDENDUM NO. 1

Date:

March 28, 2017

Issued by:

Sacramento City Unified School District

Project:

Irrigation Improvements & Outdoor Learning Area

at A.M. Winn K-8 School

You are hereby notified of the following changes, clarifications, or modifications to the original Contract Documents, Specifications, and Drawings. This Addendum shall supersede the original project documents, and shall take precedence over anything to the contrary therein. All Addenda shall be acknowledged in the Bid Form. Failure to do so may result in disqualification of the bid. All other conditions remain unchanged.

1. DRAWINGS -L1.1

- a. Tree demolition can be removed from the scope. The school district has already removed them and ground the stump.
- b. Existing irrigation controller on portable that is to be removed is to have its control valve wires extended back to the new controller. See AD1-1.

2. **DRAWING - L2.1**

a. Existing irrigation controller wires are to be spliced in a new valve box where they enter the ground next to the portable and extended to the nearby mainline and ran in the same trench back to the new controller. Wires to be connected to controller B, and to start at station 35. See AD1-2.

3. **DRAWING – L3.1**

a. There is a discrepancy between the decomposed granite detail on the Irrigation Improvements Plans and the Outdoor Learning Area Plans. The district has requested that the details for decomposed granite and metal edging on sheet L3.1 of the Irrigation Improvements Plans be used for the both projects.

END OF ADDENDUM NO. 1



