



**Business Services
Contracts Office**

5735 47th Avenue • Sacramento, CA 95824

(916) 643-2464

Gerardo Castillo, Chief Business Officer

Kimberly Teague, Contract Specialist

ADDENDUM NO. 1

Date: April 21, 2017

Issued by: Sacramento City Unified School District

Project: HVAC Replacement at Lisbon ES (Yav Pem Suab Academy)

You are hereby notified of the following changes, clarifications, or modifications to the original Contract Documents, Specifications, and Drawings. This Addendum shall supersede the original project documents, and shall take precedence over anything to the contrary therein. All Addenda shall be acknowledged in the Bid Form. Failure to do so may result in disqualification of the bid. All other conditions remain unchanged.

Question asked:

The four units in the well are sitting on vibration isolation springs. Do we re-use them or remove them and put on new sheet metal caps on the runners?

District response:

Remove them and install new sheet metal caps on the runners.

END OF ADDENDUM NO. 1