



**Business Services  
Contracts Office**

5735 47th Avenue • Sacramento, CA 95824  
(916) 643-2464

*Gerardo Castillo, Chief Business Officer  
Kimberly Teague, Contract Specialist*

**ADDENDUM NO. 1**

Date: May 22, 2017

Issued by: Sacramento City Unified School District

**Project: Irrigation Improvements at Sam Brannan MS & John Cabrillo ES**

You are hereby notified of the following changes, clarifications, or modifications to the original Contract Documents, Specifications, and Drawings. This Addendum shall supersede the original project documents, and shall take precedence over anything to the contrary therein. All Addenda shall be acknowledged in the Bid Form. Failure to do so may result in disqualification of the bid. All other conditions remain unchanged.

---

**1. DRAWINGS – L0.1**

a. New pump is being located outside of the building. Existing pump will still be removed but inlet and outlet pipes to the pump will be capped. Mainline outside of building will no longer need to be removed and replaced. Lateral lines in lawn area where the new pump yard will be located need to be removed and capped.

**2. DRAWINGS – L1.1**

a. New pump to be located outside of the building in a new pump yard along with backflow prevention device and master valve/flow sensor assembly. Booster pump model number has been updated for an enclosure. Backflow prevention device added to legend.

**3. DRAWINGS – L1.3**

a. Demo note was overlapping notes on this sheet. Demo notes were turned off so you can read the necessary note.

**4. DRAWINGS – L1.4**

a. Demo note was overlapping notes on this sheet. Demo notes were turned off so you can read the necessary note.

**5. DRAWINGS – L1.5**

a. Pipe sizing added to mainline.

**6. DRAWINGS – L1.6**

- a. Pipe sizing added to mainline.

**7. DRAWINGS – L2.1**

- a. Revised detail L2.1-4 to include enclosure for outdoor application.

**8. DRAWINGS – L2.3**

- a. Added detail L2.3-5

**REVISED DRAWINGS HAVE BEEN UPLOADED INTO E-BUILDER.**

**END OF ADDENDUM NO. 1**