



## **Business Services**

### **Contracts Office**

5735 47th Avenue • Sacramento, CA 95824

(916) 643-2464

*Gerardo Castillo, Chief Business Officer*

*Kimberly Teague, Contract Specialist*

### **ADDENDUM NO. 1**

Date: April 12, 2016

Issued by: Sacramento City Unified School District

**Project: Window System Replacement for New Joseph Bonnheim Charter School**

You are hereby notified of the following changes, clarifications, or modifications to the original Contract Documents, Specifications, and Drawings. This Addendum shall supersede the original project documents, and shall take precedence over anything to the contrary therein. All Addenda shall be acknowledged in the Bid Form. Failure to do so may result in disqualification of the bid. All other conditions remain unchanged.

---

### **SPECIFICATIONS**

#### **ITEM # 1.1** General:

- A. There were two Specifications / Project Manuals in the Bid Documents folder on e-Builder for this project. The incorrect one was deleted, and the correct one remains in this folder, titled "JosephBonnheimES-WindowWall-SPECS".
- B. Project Schedule: The work of this project will commence on June 15, 2016 and be completed no later than August 25, 2016.

**ITEM # 1.2** Bidder Responsibility Questionnaire (Section 00 21 13.1) is to be submitted with bid proposal. See Notice to Bidders, Item #7.

### **DRAWINGS**

#### **ITEM # 1.3** General:

- A. The set of plans previously in e-Builder included two other ERP projects for Joseph Bonnheim. The correct set of plans is in the Bid Documents folder on e-Builder and is titled "JosephBonnheimES-WindowWall-PLANS".

- B. Per site request, contractor to protect all landscaping and flowers during construction.
- C. Per scope of the project, doors and door panel glazing is existing to remain and will not be replaced.

**ITEM # 1.4** Sheet A201 – Exterior Glazing Elevations & Details: All 1/4" replacement glass to be laminated safety glass.

**END OF ADDENDUM NO. 1**