


NORTH

Scale 1"=100'

SITE AREA: 4.69 ACRES
A.P.N. 035-0313-005

John F. Morse K-8 School (173)
1901 60th Avenue
SACRAMENTO CITY UNIFIED SCHOOL DISTRICT


AHERA Management Plan




JOHN MORSE

DRAWING No.	1
SPACE	
FLOOR	1st


BLD P02



BLD P03



BLD 004



JOHN MORSE

DRAWING No.	2
SPACE	
FLOOR	1st

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 173		JOHN MORSE				Address: 1901 60TH AVENUE, Sacramento 95822				
Building No:	001	Room	B001	Description	Boiler Room		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	168	SF	Non ASB	Sampled	0	C1008	
Mechanical	Boiler Seal Compound	T	N		SF	Other	Assumed	N/A		
Mechanical	Flue	M	N	4	LF	Other	Assumed	N/A		
Mechanical	Gasket	M	N	8	SF	Other	Assumed	N/A		
Piping	Heat Hot Water Insulation	T	Y	26	LF	Other	Assumed	N/A		
Wall	Fire Rated Door	M	N	21	SF	Other	Assumed	N/A		
Wall	Plaster	S	N	320	SF	Non ASB	Sampled	0	B2930	

Building No:	001	Room	C001	Description	Office		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	144	SF	Non ASB	Sampled	0	T2014	
Wall	Fire Rated Door	M	N	21	SF	Other	Assumed	N/A		

Building No:	001	Room	C002	Description	Office		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	260	SF	Non ASB	Sampled	0	T2014	
Flooring	Tile 12 In.	M	N	360	SF	Non ASB	Sampled	0	B6014	Under Carpet
Wall	Plaster	S	N	320	SF	Non ASB	Sampled	0	B2930	

Building No:	001	Room	C003	Description	Office		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	220	SF	Non ASB	Sampled	0	T2014	
Flooring	Tile 12 In.	M	N	220	SF	Non ASB	Sampled	0	B6014	

Building No:	001	Room	H001	Description	Hallway/Stairs		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	620	SF	Non ASB	Sampled	0	T2014	
Flooring	Tile 12 In.	M	N	600	SF	Non ASB	Sampled	0	B6014	
Wall	Plaster	S	N	700	SF	Non ASB	Sampled	0	B2930	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 2 of 10

SITE: 173		JOHN MORSE				Address: 1901 60TH AVENUE, Sacramento 95822				
Building No:	001	Room	I001	Description	Lounge		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	156	SF	Non ASB	Sampled	0	T2014	
Flooring	Tile 12 In.	M	N		SF	Non ASB	Sampled	0	B1417	
Wall	Plaster	S	N	530	SF	Non ASB	Sampled	0	B2930	

Building No:	001	Room	J001	Description	Custodial Closet		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	96	SF	Non ASB	Sampled	0	C1008	
Flooring	Tile 12 In.	M	N	50	SF	Non ASB	Sampled	0	T2006	
Wall	Plaster	S	N	160	SF	Non ASB	Sampled	0	B2930	

Building No:	001	Room	O001	Description	Classroom		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	900	SF	Non ASB	Sampled	0	T2014	
Ceiling	Sheet Rock	M	N		SF	Non ASB	Sampled	0	B1403	
Flooring	Tile 12 In.	M	N	1200	SF	Non ASB	Sampled	0		
Wall	Sheet Rock	M	N		SF	Non ASB	Sampled	0	B1412	
Wall	Transite Chalk Board	M	N	31	SF	Other	Assumed	N/A		

Building No:	001	Room	O002	Description	Classroom		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	900	SF	Non ASB	Sampled	0	T2014	
Ceiling	Sheet Rock	M	N		SF	Non ASB	Sampled	0	B1403	
Flooring	Tile 12 In.	M	N	1200	SF	Non ASB	Sampled	0		
Wall	Plaster	S	N	320	SF	Non ASB	Sampled	0	B2930	
Wall	Sheet Rock	M	N		SF	Non ASB	Sampled	0	B1412	

Building No:	001	Room	S001	Description	Storage		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	120	SF	Non ASB	Sampled	0	C1008	
Wall	Plaster	S	N	530	SF	Non ASB	Sampled	0	B2930	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 173		JOHN MORSE				Address: 1901 60TH AVENUE, Sacramento 95822				
Building No:	001	Room	S002	Description	Storage		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	100	SF	Non ASB	Sampled	0	C1008	
Flooring	Tile 12 In.	M	N	101	SF	Non ASB	Sampled	0	B6014	
Wall	Plaster	S	N	140	SF	Non ASB	Sampled	0	B2930	

Building No:	001	Room	S003	Description	Storage		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	210	SF	Non ASB	Sampled	0	C1008	
Wall	Plaster	S	N	120	SF	Non ASB	Sampled	0	B2930	

Building No:	001	Room	S004	Description	Storage		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	64	SF	Non ASB	Sampled	0	C1008	
Flooring	Tile 12 In.	M	N	35	SF	Non ASB	Sampled	0		

Building No:	001	Room	S005	Description	Storage		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	96	SF	Non ASB	Sampled	0	C1008	
Flooring	Tile 12 In.	M	N	96	SF	Non ASB	Sampled	0	B6014	
Wall	Plaster	S	N	140	SF	Non ASB	Sampled	0	B2930	

Building No:	001	Room	S006	Description	Storage		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	64	SF	Non ASB	Sampled	0	C1008	
Flooring	Tile 12 In.	M	N	35	SF	Non ASB	Sampled	0		

Building No:	001	Room	T001	Description	Toilet		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	64	SF	Non ASB	Sampled	0	C1008	
Flooring	Vinyl Sheet	M	N	64	SF	Non ASB	Sampled	0		
Wall	Fire Rated Door	M	N	21	SF	Other	Assumed	N/A		

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 173		JOHN MORSE				Address: 1901 60TH AVENUE, Sacramento 95822					
Building No:	001	Room	T002	Description		Toilet		Drawing No:	1		
Location		Homogeneous Material		Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling		Plaster		S	N	64 SF		Non ASB	Sampled	0	C1008
Wall		Sheet Rock		M	N	SF		Non ASB	Sampled	0	B1412

Building No:	001	Room	T003	Description		Toilet		Drawing No:	1		
Location		Homogeneous Material		Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling		Plaster		S	N	40 SF		Non ASB	Sampled	0	C1008
Wall		Plaster		S	N	170 SF		Non ASB	Sampled	0	B2930

Building No:	001	Room	T004	Description		Toilet		Drawing No:	1		
Location		Homogeneous Material		Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling		Plaster		S	N	64 SF		Non ASB	Sampled	0	C1008
Flooring		Vinyl Sheet		M	N	SF		Non ASB	Sampled	0	B1414

Building No:	001	Room	T005	Description		Toilet		Drawing No:	1		
Location		Homogeneous Material		Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling		Plaster		S	N	40 SF		Non ASB	Sampled	0	C1008
Wall		Plaster		S	N	74 SF		Non ASB	Sampled	0	B2930

Building No:	001	Room	Z001	Description		Misc. Room		Drawing No:	1		
Location		Homogeneous Material		Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling		Acoustical Tile, Splined		M	N	220 SF		Non ASB	Sampled	0	T2014
Flooring		Tile 12 In.		M	N	190 SF		Non ASB	Sampled	0	B6014
Wall		Plaster		S	N	104 SF		Non ASB	Sampled	0	B2930

Building No:	001	Room	ZEXT	Description		Exterior		Drawing No:	1		
Location		Homogeneous Material		Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #
Exterior, Wall		Plaster		S	N	4000 SF		Non ASB	Sampled	0	B2927

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 173		JOHN MORSE				Address: 1901 60TH AVENUE, Sacramento 95822				
Building No:	002	Room	B002	Description	Boiler Room		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	100	SF	Non ASB	Sampled	0	C1015	
Mechanical	Boiler Seal Compound	T	N		SF	Other	Assumed	N/A		
Mechanical	Flue	M	N	8	LF	Other	Assumed	N/A		
Piping	Heat Hot Water Insulation	T	N	24	LF	Other	Assumed	N/A		
Wall	Fire Rated Door	M	N	21	SF	Other	Assumed	N/A		
Wall	Plaster	S	N	290	SF	Non ASB	Sampled	0	B2940	

Building No:	002	Room	C001	Description	Office		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	110	SF	Non ASB	Sampled	0	C1015	
Wall	Fire Rated Door	M	N	21	SF	Other	Assumed	N/A		
Wall	Plaster	S	N	300	SF	Non ASB	Sampled	0	B2940	

Building No:	002	Room	O003	Description	Classroom		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	900	SF	Non ASB	Sampled	0	T2017	
Flooring	Tile 12 In.	M	N		SF	Non ASB	Sampled	0	B1417	
Wall	Plaster	S	N	1200	SF	Non ASB	Sampled	0	B2940	

Building No:	002	Room	O004	Description	Classroom		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	960	SF	Non ASB	Sampled	0	T2017	
Flooring	Tile 12 In.	M	N		SF	Non ASB	Sampled	0	B1419	
Wall	Plaster	S	N	144	SF	Non ASB	Sampled	0	B2940	
Wall	Transite Chalk Board	M	N	32	SF	Other	Assumed	N/A		

Building No:	002	Room	O005	Description	Classroom		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	900	SF	Non ASB	Sampled	0	T2017	
Flooring	Tile 12 In.	M	N	960	SF	Non ASB	Sampled	0	B2926	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 173		JOHN MORSE				Address: 1901 60TH AVENUE, Sacramento 95822				
Building No:	002	Room	O006	Description	Classroom		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	0 SF		Non ASB	Sampled	0	100B00	
Flooring	Tile 12 In.	M	N	960 SF		Non ASB	Sampled	0	B2926	
Wall	Transite Chalk Board	M	N	32 SF		Other	Assumed	N/A		

Building No:	002	Room	O007	Description	Classroom		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	900 SF		Non ASB	Sampled	0	T2017	
Flooring	Tile 12 In.	M	N	960 SF		Non ASB	Sampled	0	B2926	
Wall	Transite Chalk Board	M	N	32 SF		Other	Assumed	N/A		

Building No:	002	Room	T001	Description	Toilet		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	35 SF		Non ASB	Sampled	0	C1015	
Flooring	Vinyl Sheet	M	N	SF		Non ASB	Sampled	0	B1418	
Wall	Plaster	S	N	96 SF		Non ASB	Sampled	0	B2940	

Building No:	002	Room	T002	Description	Toilet		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	35 SF		Non ASB	Sampled	0	C1015	
Wall	Plaster	S	N	96 SF		Non ASB	Sampled	0	B2940	

Building No:	002	Room	T003	Description	Toilet		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Wall	Fire Rated Door	M	N	21 SF		Other	Assumed	N/A		
Wall	Plaster	S	N	200 SF		Non ASB	Sampled	0	B2940	

Building No:	002	Room	T004	Description	Toilet		Drawing No:	1		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Wall	Fire Rated Door	M	N	21 SF		Other	Assumed	N/A		
Wall	Plaster	S	N	200 SF		Non ASB	Sampled	0	B2940	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 173 | **JOHN MORSE** | **Address: 1901 60TH AVENUE, Sacramento 95822**

Building No: 002 | **Room ZC01** | **Description Pipe Chase** | **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Wall	Plaster	S	N	260 SF	Non ASB	Sampled	0	T2015
Wall	Unspecified	S	N	0 SF	Non ASB	Sampled	0	001B00

Building No: 002 | **Room ZEXT** | **Description Exterior** | **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Exterior, Wall	Asbestos Cement Panel	M	N	21 SF	Other	Assumed	N/A	
Exterior, Wall	Plaster	S	N	4000 SF	Non ASB	Sampled	0	B2937

Building No: 003 | **Room S001** | **Description Storage** | **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	120 SF	Non ASB	Sampled	0	C1018
Wall	Fire Rated Door	M	N	21 SF	Other	Assumed	N/A	
Wall	Plaster	S	N	480 SF	Non ASB	Sampled	0	B2948

Building No: 003 | **Room S002** | **Description Storage** | **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	120 SF	Non ASB	Sampled	0	C1018
Flooring	Tile 12 In.	m	N	500 SF	Non ASB	Sampled	0	B1833
Wall	Fire Rated Door	M	N	21 SF	Other	Assumed	N/A	
Wall	Plaster	S	N	480 SF	Non ASB	Sampled	0	B2948

Building No: 003 | **Room ZEXT** | **Description Exterior** | **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Exterior, Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	B2945

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 8 of 10

SITE: 173 **JOHN MORSE** Address: 1901 60TH AVENUE, Sacramento 95822

Building No: 004 Room K001 Description Kitchen Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	300 SF	Non ASB	Sampled	0	P2020	
Flooring	Mastic	m	N	300 SF	Serp	Sampled	5	B3254A	Black mastic only
Flooring	Tile 12 In.	m	N	300 SF	Non ASB	Sampled	0	B3254A	Top layer, Gray
Flooring	Vinyl Sheet	M	N	300 SF	Serp	Sampled	25	B3254C	Under upper flooring & wood underlayment
Wall	Sheet Rock	M	N	SF	Non ASB	Sampled	0	B1412	

Building No: 004 Room O001 Description Classroom Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	960 SF	Non ASB	Sampled	0	B6007	
Flooring	Tile 12 In.	M	N	SF	Non ASB	Sampled	0	B1419	
Wall	Sheet Rock	M	N	SF	Non ASB	Sampled	0	B1412	

Building No: 004 Room T001 Description Toilet Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	64 SF	Serp	Sampled	5	B1004	
Wall	Sheet Rock	M	N	64 SF	Serp	Sampled	5	B2923	

Building No: 004 Room T002 Description Toilet Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	64 SF	Serp	Sampled	5	B1004	
Wall	Sheet Rock	M	N	64 SF	Serp	Sampled	5	B2923	

Building No: 004 Room U001 Description Multipurpose/Cafeteria Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	0 SF	Non ASB	Sampled	0	101B00	
Flooring	Tile 12 In.	M	N	2500 SF	Non ASB	Sampled	0	B6010	
Wall	Acoustical Tile, Splined	M	N	SF	Non ASB	Sampled	0	P2020	
Wall	Sheet Rock	M	N	SF	Non ASB	Sampled	0	B1412	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 173		JOHN MORSE				Address: 1901 60TH AVENUE, Sacramento 95822					
Building No:	004	Room	ZEXT	Description	Exterior		Drawing No:	2			
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #		
Exterior, Wall	Plaster	S	N	3000	SF	Non ASB	Sampled	0	B6011		

Building No:	P01	Room	O008	Description	Classroom		Drawing No:	1			
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Acoustical Tile, Splined	M	N	900	SF	Non ASB	Sampled	0			
Flooring	Tile 12 In.	M	N	960	SF	Non ASB	Sampled	0	C1007	Under newer flooring	
HVAC	Flue	M	N	5	LF	Other	Assumed	N/A			
Wall	Sheet Rock	M	N		SF	Non ASB	Sampled	0	013B00		
Wall	Transite Chalk Board	M	N	31	SF	Other	Assumed	N/A			

Building No:	P01	Room	O009	Description	Classroom		Drawing No:	1			
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Acoustical Tile, Splined	M	N	900	SF	Non ASB	Sampled	0	P2011		
Flooring	Tile 12 In.	M	N	960	SF	Non ASB	Sampled	0	C1007		
HVAC	Flex Joint	M	N	6	SF	Other	Assumed	N/A			
Wall	Sheet Rock	M	N	0	SF	Non ASB	Sampled	0	013B00		

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 173		JOHN MORSE			Address: 1901 60TH AVENUE, Sacramento 95822				
Building No:	P02	Room	O011	Description	Classroom	Drawing No:	2	Built With Non-Asbestos Materials	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P02	Room	O012	Description	Classroom	Drawing No:	2	Built With Non-Asbestos Materials	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P02	Room	O013	Description	Classroom	Drawing No:	2	Built With Non-Asbestos Materials	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P02	Room	O014	Description	Classroom	Drawing No:	2	Built With Non-Asbestos Materials	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	P03	Room	O001	Description	Classroom	Drawing No:	2	Built With Non-Asbestos Materials	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	