



NORTH

A. W. McClaskey Adult School (594)
5241 J Street
Sacramento City Unified School District

AHERA Management Plan




BLD 001



NORTH

A. W. McCLASKEY


DRAWING NO.	1
SPACE	
FLOOR	BASEMENT



DRAWING NO.	2
SPACE	
FLOOR	


A. W. McCLASKEY





BLD 002

BLD 001 (SECOND FLOOR)




ZA06

ZA05

ZA04


BLD 001 (FIRST FLOOR)



ZA02

ZA01

ZA03




NORTH


DRAWING NO.	3
SPACE	ATTIC
FLOOR	

A. W. McCLASKEY

BLD P01




BLD 003



NORTH

A. W. McCLASKEY

DRAWING NO.	4
SPACE	
FLOOR	1st



A. W. McCLASKEY

DRAWING NO.	5
SPACE	ATTIC
FLOOR	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 594 A. WARREN MCCLASKEY Address: 5241 J STREET, Sacramento 95819

Building No: 001 Room B001 Description Boiler Room Drawing No: 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Kiln	Kiln Block	M	Y	2 SF	Non ASB	Sampled	0	E1013
Mechanical	Boiler Insulation - Exterior	T	N	120 SF	Other	Assumed	N/A	
Misc.	Table/Counter Top	M	Y	6 SF	Non ASB	Sampled	0	B3262 Brown mastic non-asbestos
Piping	Steam Insulation	T	N	95 LF	Other	Assumed	N/A	

Building No: 001 Room C007 Description Office Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	270 SF	Serp	Sampled	15	003H00
Wall	Plaster	S	N	320 SF	Non ASB	Sampled	0	D8095

Building No: 001 Room C009 Description Office Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	96 SF	Serp	Sampled	15	003H00
Wall	Plaster	S	N	225 SF	Non ASB	Sampled	0	D8095

Building No: 001 Room C010 Description Office Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	120 SF	Serp	Sampled	15	003H00
Wall	Plaster	S	N	225 SF	Non ASB	Sampled	0	D8095

Building No: 001 Room H004 Description Hallway/Stairs Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #

Building No: 001 Room H005 Description Hallway/Stairs Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	0 SF	Non ASB	Sampled	0	E2071

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 594 **A. WARREN MCCLASKEY** **Address: 5241 J STREET, Sacramento 95819**

Building No: 001 **Room H013** **Description Hallway/Stairs** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	0 SF	Non ASB	Sampled	0	E2071

Building No: 001 **Room H018** **Description Hallway/Stairs** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	2000 SF	Serp	Sampled	15	003H00
Ceiling	Plaster	S	N	2000 SF	Non ASB	Sampled	0	E2071
Wall	Plaster	S	N	800 SF	Non ASB	Sampled	0	D8095

Building No: 001 **Room H024** **Description Hallway/Stairs** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	2000 SF	Non ASB	Sampled	0	E2071
Wall	Plaster	S	N	350 SF	Non ASB	Sampled	0	D8095

Building No: 001 **Room H025** **Description Hallway/Stairs** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	270 SF	Serp	Sampled	15	003H00
Ceiling	Plaster	S	N	270 SF	Non ASB	Sampled	0	E2071
Flooring	Vinyl Sheet	M	N	270 SF	Non ASB	Sampled	0	E2078
Wall	Plaster	S	N	700 SF	Non ASB	Sampled	0	D8095

Building No: 001 **Room J020** **Description Custodial Closet** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	96 SF	Non ASB	Sampled	0	E2071
Wall	Plaster	S	N	120 SF	Non ASB	Sampled	0	D8095

Building No: 001 **Room J023** **Description Custodial Closet** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	64 SF	Non ASB	Sampled	0	E2071
Wall	Plaster	S	N	110 SF	Non ASB	Sampled	0	D8095

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 3 of 22

SITE: 594 A. WARREN MCCLASKEY Address: 5241 J STREET, Sacramento 95819

Building No: 001 Room O001 Description Classroom Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Tile, Lay In	M	N	900 SF	Non ASB	Sampled	0	006H00
Ceiling	Plaster	S	N	900 SF	Non ASB	Sampled	0	E2071
Flooring	Mastic	m	N	SF	Non ASB	Sampled	0	B3360
Flooring	Tile 12 In.	m	N	SF	Non ASB	Sampled	0	B3366
Flooring	Vinyl Sheet	m	N	SF	Non ASB	Sampled	0	B3360 Under newer floor
Wall	Plaster	S	N	620 SF	Non ASB	Sampled	0	D8095

Building No: 001 Room O002 Description Classroom Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Tile, Lay In	M	N	0 SF	Non ASB	Sampled	0	006H00
Ceiling	Plaster	S	N	720 SF	Non ASB	Sampled	0	E2071
Flooring	Tile 12 In.	m	N	SF	Non ASB	Sampled	0	B3366
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095

Building No: 001 Room O003 Description Classroom Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Tile, Lay In	M	N	0 SF	Non ASB	Sampled	0	006B00
Ceiling	Plaster	S	N	720 SF	Non ASB	Sampled	0	E2071
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095

Building No: 001 Room O004 Description Classroom Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	720 SF	Serp	Sampled	15	003H00
Ceiling	Acoustical Tile, Lay In	M	N	0 SF	Non ASB	Sampled	0	006H00
Ceiling	Plaster	S	N	720 SF	Non ASB	Sampled	0	E2071
Flooring	Vinyl Sheet	M	N	720 SF	Non ASB	Sampled	0	E2078
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095
Wall	Transite Chalk Board	M	N	42 SF	Other	Assumed	N/A	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 4 of 22

SITE: 594 A. WARREN MCCLASKEY Address: 5241 J STREET, Sacramento 95819

Building No: 001 Room O005 Description Classroom Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Tile, Splined	M	N	720 SF	Non ASB	Sampled	0	E2079
Ceiling	Plaster	S	N	720 SF	Non ASB	Sampled	0	E2071
Flooring	Vinyl Sheet	M	N	720 SF	Non ASB	Sampled	0	E2078
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095
Wall	Transite Chalk Board	M	N	64 SF	Other	Assumed	N/A	

Building No: 001 Room O006 Description Classroom Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	720 SF	Serp	Sampled	15	003H00
Ceiling	Acoustical Tile, Lay In	M	N	0 SF	Non ASB	Sampled	0	006B00
Ceiling	Plaster	S	N	720 SF	Non ASB	Sampled	0	E2071
Flooring	Vinyl Sheet	M	N	720 SF	Non ASB	Sampled	0	E2078
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095
Wall	Transite Chalk Board	M	N	64 SF	Other	Assumed	N/A	

Building No: 001 Room O007 Description Classroom Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	720 SF	Serp	Sampled	15	003H00
Flooring	Vinyl Sheet	M	N	720 SF	Non ASB	Sampled	0	E2078
Wall	Acoustical Texture	S	N	500 SF	Serp	Sampled	5	003H00
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095

Building No: 001 Room O009 Description Classroom Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	720 SF	Serp	Sampled	15	003H00
Ceiling	Acoustical Tile, Splined	M	N	720 SF	Non ASB	Sampled	0	E2079
Ceiling	Plaster	S	N	720 SF	Non ASB	Sampled	0	E2071
Flooring	Vinyl Sheet	M	N	720 SF	Non ASB	Sampled	0	E2078
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095
Wall	Transite Chalk Board	M	N	64 SF	Other	Assumed	N/A	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 5 of 22

SITE: 594		A. WARREN MCCLASKEY			Address: 5241 J STREET, Sacramento 95819					
Building No:	001	Room	O010	Description	Classroom		Drawing No:	2		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	720	SF	Non ASB	Sampled	0	E2071	
Flooring	Vinyl Sheet	M	N	720	SF	Non ASB	Sampled	0	E2078	
Wall	Acoustical Texture	S	N	500	SF	Serp	Sampled	5	003H00	
Wall	Plaster	S	N	400	SF	Non ASB	Sampled	0	D8095	
Wall	Transite Chalk Board	M	N	64	SF	Other	Assumed	N/A		

Building No:	001	Room	O011	Description	Classroom		Drawing No:	2	
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	720	SF	Non ASB	Sampled	0	E2071
Flooring	Vinyl Sheet	M	N	720	SF	Non ASB	Sampled	0	E2078
Wall	Acoustical Texture	S	N	500	SF	Serp	Sampled	5	003H00
Wall	Plaster	S	N	400	SF	Non ASB	Sampled	0	D8095
Wall	Transite Chalk Board	M	N	126	SF	Other	Assumed	N/A	

Building No:	001	Room	O012	Description	Classroom		Drawing No:	2	
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	720	SF	Non ASB	Sampled	0	E2071
Flooring	Vinyl Sheet	M	N	720	SF	Non ASB	Sampled	0	E2078
Wall	Acoustical Texture	S	N	500	SF	Serp	Sampled	5	003H00
Wall	Plaster	S	N	400	SF	Non ASB	Sampled	0	D8095

Building No:	001	Room	S002	Description	Storage		Drawing No:	2	
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	226	SF	Non ASB	Sampled	0	E2071
Flooring	Mastic	m	N		SF	Non ASB	Sampled	0	B3360
Flooring	Tile 12 In.	m	N		SF	Non ASB	Sampled	0	B3366
Flooring	Vinyl Sheet	M	N	226	SF	Non ASB	Sampled	0	E2078 Under newer flooring
Flooring	Vinyl Sheet	m	N		SF	Non ASB	Sampled	0	B3360
Wall	Plaster	S	N	250	SF	Non ASB	Sampled	0	D8095

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 6 of 22

SITE: 594 **A. WARREN MCCLASKEY** **Address: 5241 J STREET, Sacramento 95819**

Building No: 001 **Room S006** **Description** **Storage** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Wall	Plaster	S	N	340 SF	Non ASB	Sampled	0	D8095

Building No: 001 **Room S008** **Description** **Storage** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Wall	Plaster	S	N	225 SF	Non ASB	Sampled	0	D8095

Building No: 001 **Room S012** **Description** **Storage** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	120 SF	Non ASB	Sampled	0	E2071
Flooring	Mastic	m	N	SF	Non ASB	Sampled	0	B3360
Flooring	Vinyl Sheet	m	N	120 SF	Non ASB	Sampled	0	B3360
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095

Building No: 001 **Room S014** **Description** **Storage** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095

Building No: 001 **Room S015** **Description** **Storage** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095

Building No: 001 **Room S016** **Description** **Storage** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Flooring	Vinyl Sheet	M	N	75 SF	Non ASB	Sampled	0	E2078
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8059

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 594 **A. WARREN MCCLASKEY** **Address: 5241 J STREET, Sacramento 95819**

Building No: 001 **Room S017** **Description** **Storage** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Flooring	Vinyl Sheet	M	N	75 SF	Non ASB	Sampled	0	E2078
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095

Building No: 001 **Room S018** **Description** **Storage** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	181 SF	Non ASB	Sampled	0	E2071
Flooring	Vinyl Sheet	M	N	181 SF	Non ASB	Sampled	0	E2078
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095

Building No: 001 **Room S019** **Description** **Storage** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	120 SF	Non ASB	Sampled	0	E2071
Flooring	Vinyl Sheet	M	N	120 SF	Non ASB	Sampled	0	E2078
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095

Building No: 001 **Room S020** **Description** **Storage** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	120 SF	Non ASB	Sampled	0	E2071
Flooring	Vinyl Sheet	M	N	240 SF	Non ASB	Sampled	0	E2078
Wall	Plaster	S	N	400 SF	Non ASB	Sampled	0	D8095

Building No: 001 **Room S09A** **Description** **Storage** **Drawing No: 2**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	200 SF	Non ASB	Sampled	0	E2071
Flooring	Vinyl Sheet	M	N	200 SF	Non ASB	Sampled	0	E2078
Wall	Plaster	S	N	480 SF	Non ASB	Sampled	0	D8095

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 594		A. WARREN MCCLASKEY			Address: 5241 J STREET, Sacramento 95819					
Building No:	001	Room	S09B	Description	Storage		Drawing No:	2		
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Plaster	S	N	200 SF	Non ASB	Sampled	0	E2071		
Flooring	Vinyl Sheet	M	N	200 SF	Non ASB	Sampled	0	E2078		
Wall	Plaster	S	N	480 SF	Non ASB	Sampled	0	D8095		

Building No:	001	Room	S10A	Description	Storage		Drawing No:	2		
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Plaster	S	N	200 SF	Non ASB	Sampled	0	E2071		
Wall	Plaster	S	N	480 SF	Non ASB	Sampled	0	D8095		

Building No:	001	Room	S11A	Description	Storage		Drawing No:	2		
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Plaster	S	N	120 SF	Non ASB	Sampled	0	E2071		
Wall	Plaster	S	N	480 SF	Non ASB	Sampled	0	D8095		

Building No:	001	Room	S11B	Description	Storage		Drawing No:	2		
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Plaster	S	N	120 SF	Non ASB	Sampled	0	E2071		
Wall	Plaster	S	N	480 SF	Non ASB	Sampled	0	D8095		

Building No:	001	Room	S12A	Description	Storage		Drawing No:	2		
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Plaster	S	N	180 SF	Non ASB	Sampled	0	E2071		
Wall	Plaster	S	N	480 SF	Non ASB	Sampled	0	D8095		

Building No:	001	Room	S12B	Description	Storage		Drawing No:	2		
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Plaster	S	N	120 SF	Non ASB	Sampled	0	E2071		
Wall	Plaster	S	N	480 SF	Non ASB	Sampled	0	D8095		

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 594		A. WARREN MCCLASKEY				Address: 5241 J STREET, Sacramento 95819				
Building No:	001	Room	T001	Description		Toilet		Drawing No:	2	
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Plaster	S	N	280	SF	Non ASB	Sampled	0	E2071	
Flooring	Mastic	m	N		SF	Non ASB	Sampled	0	B3360	
Flooring	Tile 12 In.	m	N		SF	Non ASB	Sampled	0	B3366	
Flooring	Vinyl Sheet	m	N	280	SF	Non ASB	Sampled	0	B3360	
Wall	Plaster	S	N	730	SF	Non ASB	Sampled	0	D8095	

Building No:	001	Room	T011	Description		Toilet		Drawing No:	2	
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Flooring	Vinyl Sheet	M	N	64	SF	Other	Assumed	N/A		Under Carpets
Wall	Plaster	S	N	250	SF	Non ASB	Sampled	0	D8095	

Building No:	001	Room	T012	Description		Toilet		Drawing No:	2	
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Flooring	Mastic	m	N		SF	Non ASB	Sampled	0	B3360	
Flooring	Vinyl Sheet	m	N	64	SF	Non ASB	Sampled	0	B3360	
Wall	Plaster	S	N	250	SF	Non ASB	Sampled	0	D8095	

Building No:	001	Room	T013	Description		Toilet		Drawing No:	2	Built With Non-Asbestos Materials
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	001	Room	T014	Description		Toilet		Drawing No:	2	Built With Non-Asbestos Materials
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	

Building No:	001	Room	U013	Description		Multipurpose/Cafeteria		Drawing No:	2	
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Texture	S	N	280	SF	Serp	Sampled	15	003H00	
Wall	Acoustical Texture	S	N	2100	SF	Serp	Sampled	5	003H00	
Wall	Plaster	S	N	390	SF	Non ASB	Sampled	0	D8095	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 594 **A. WARREN MCCLASKEY** **Address: 5241 J STREET, Sacramento 95819**

Building No: 001 **Room ZA01** **Description Attic** **Drawing No: 3**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Wall	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	007B00

Building No: 001 **Room ZA02** **Description Attic** **Drawing No: 3**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Wall	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	007B00

Building No: 001 **Room ZA03** **Description Attic** **Drawing No: 3**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Wall	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	007B00

Building No: 001 **Room ZA04** **Description Attic** **Drawing No: 3**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Wall	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	007B00

Building No: 001 **Room ZA05** **Description Attic** **Drawing No: 3**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Wall	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	007B00

Building No: 001 **Room ZC01** **Description Crawl Space** **Drawing No: 2** **No Suspect Materials Present**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
----------	----------------------	-------	---------	---------------	------------------	-------------	------------	----------

Building No: 001 **Room ZC02** **Description Crawl Space** **Drawing No: 1**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Misc.	Debris	M	Y	0 SF	Other	Assumed	N/A	
Piping	Steam Insulation	T	Y	150 LF	Other	Assumed	N/A	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 11 of 22

SITE: 594 **A. WARREN MCCLASKEY** **Address: 5241 J STREET, Sacramento 95819**

Building No: 001 **Room** ZC03 **Description** Crawl Space **Drawing No:** 1

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Misc.	Debris	M	Y	0 SF	Other	Assumed	N/A	
Piping	Steam Insulation	T	Y	450 LF	Other	Assumed	N/A	

Building No: 001 **Room** ZEXT **Description** Exterior **Drawing No:** 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Exterior, Wall	Plaster	S	N	9000 SF	Non ASB	Sampled	0	C6071

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 12 of 22

SITE: 594 A. WARREN MCCLASKEY Address: 5241 J STREET, Sacramento 95819

Building No: 002 Room: K201 Description: Kitchen Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Flooring	Mastic	m	N	SF	Non ASB	Sampled	0	B3384	Under Vinyl Sheet
Flooring	Tile 12 In.	M	N	380 SF	Serp	Sampled	2	D9002	
Flooring	Tile 9 In. & Floor Mastic	m	N	20 SF	Other	Assumed	N/A		
Flooring	Vinyl Sheet	m	N	380 SF	Non ASB	Sampled	0	B3384	
Wall	Mastic	M	N	SF	Non ASB	Sampled		J1630	

Building No: 002 Room: M200 Description: Mechanical Room Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	64 SF	Serp	Sampled	5	011H00	
Flooring	Tile 9 In. & Floor Mastic	m	N	20 SF	Other	Assumed	N/A		
HVAC	Flex Joint	M	N	6 SF	Other	Assumed	N/A		
HVAC	Flue	M	N	3 LF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	48 SF	Serp	Sampled	5	011B00	

Building No: 002 Room: M201 Description: Mechanical Room Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	96 SF	Serp	Sampled	5	011H00	
Wall	Sheet Rock	M	N	48 SF	Serp	Sampled	5	011B00	

Building No: 002 Room: M202 Description: Mechanical Room Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	64 SF	Serp	Sampled	5	011H00	
HVAC	Flex Joint	M	N	5 SF	Other	Assumed	N/A		
HVAC	Flue	M	N	3 LF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	48 SF	Serp	Sampled	5	011B00	

Building No: 002 Room: S201 Description: Storage Drawing No: 2

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Sheet Rock	M	N	95 SF	Serp	Sampled	5	E2092	
Flooring	Tile 12 In.	M	N	96 SF	Serp	Sampled	2	D9002	
Wall	Sheet Rock	M	N	65 SF	Serp	Sampled	5	011B00	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 13 of 22

SITE: 594		A. WARREN MCCLASKEY			Address: 5241 J STREET, Sacramento 95819				
Building No:	002	Room	S202	Description	Storage		Drawing No:	2	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Flooring	Tile 9 In. & Floor Mastic	M	N	96 SF	Other	Assumed		N/A	

Building No:	002	Room	T201	Description	Toilet		Drawing No:	2	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	96 SF	Non ASB	Sampled	0	E2080	
Flooring	Mastic	m	N	SF	Non ASB	Sampled	0	B3388	
Flooring	Vinyl Sheet	m	N	SF	Non ASB	Sampled	0	B3388	

Building No:	002	Room	U001	Description	Multipurpose/Cafeteria		Drawing No:	2	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Splined	M	N	2200 SF	Non ASB	Sampled	0	E2080	
Flooring	Tile 9 In. & Floor Mastic	M	N	2200 SF	Other	Assumed		N/A	
Kiln	Kiln Block	M	N	10 SF	Non ASB	Sampled	0	T1975	

Building No:	002	Room	ZEXT	Description	Exterior		Drawing No:	2	
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #	
Exterior, Wall	Non Asbestos, Hardy Panel	m	N	SF	Non ASB	Sampled	0	B3389	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 14 of 22

SITE: 594 A. WARREN MCCLASKEY Address: 5241 J STREET, Sacramento 95819

Building No: 003 Room A301 Description Auditorium Drawing No: 4

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Fiberboard	m	N	2000 SF	Non ASB	Sampled	0	B1750
Ceiling	Plaster	S	N	1000 SF	Non ASB	Sampled	0	E2098
Wall	Plaster	S	N	1000 SF	Non ASB	Sampled	0	E2083

Building No: 003 Room A302 Description Auditorium Drawing No: 4

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	2600 SF	Non ASB	Sampled	0	E2098
Wall	Plaster	S	N	17000 SF	Non ASB	Sampled	0	E2083

Building No: 003 Room C304 Description Office Drawing No: 4

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	220 SF	Serp	Sampled	5	003H00
Ceiling	Acoustical Tile, Lay In	m	N	SF	Non ASB	Sampled	0	B1753
Ceiling	Acoustical Tile, Splined	m	N	220 SF	Non ASB	Sampled	0	B1945
Ceiling	Plaster	S	N	400 SF	Non ASB	Sampled	0	E2098
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	10	011H00
Exterior, Wall	Asbestos Cement Panel	m	N	500 SF	Other	Assumed	N/A	
Wall	Plaster	S	N	560 SF	Non ASB	Sampled	0	E2083

Building No: 003 Room C305 Description Office Drawing No: 4

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	200 SF	Serp	Sampled	5	003H00
Ceiling	Acoustical Tile, Splined	m	N	200 SF	Non ASB	Sampled	0	B1945
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	10	011H00
Exterior, Wall	Asbestos Cement Panel	m	N	150 SF	Other	Assumed	N/A	
Flooring	Tile 9 In. & Floor Mastic	M	N	200 SF	Other	Assumed	N/A	Under carpet

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 594 **A. WARREN MCCLASKEY** **Address: 5241 J STREET, Sacramento 95819**

Building No: 003 **Room C306** **Description Office** **Drawing No: 4**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	200 SF	Serp	Sampled	5	003H00
Ceiling	Acoustical Tile, Splined	m	N	299 SF	Non ASB	Sampled	0	B1945
Ceiling	Sheet Rock	M	N	100 SF	Serp	Sampled	10	011H00
Flooring	Tile 9 In. & Floor Mastic	M	N	200 SF	Other	Assumed	N/A	
Wall	Asbestos Cement Panel	m	N	150 SF	Other	Assumed	N/A	

Building No: 003 **Room H302** **Description Hallway/Stairs** **Drawing No: 4**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	1200 SF	Non ASB	Sampled	0	E2098
Wall	Plaster	S	N	2000 SF	Non ASB	Sampled	0	E2083

Building No: 003 **Room H303** **Description Hallway/Stairs** **Drawing No: 4**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	200 SF	Serp	Sampled	5	003H00
Ceiling	Plaster	S	N	800 SF	Non ASB	Sampled	0	E2098
Wall	Plaster	S	N	21000 SF	Non ASB	Sampled	0	E2083

Building No: 003 **Room H304** **Description Hallway/Stairs** **Drawing No: 4**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	220 SF	Serp	Sampled	5	003H00
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	10	011H00
Flooring	Tile 9 In. & Floor Mastic	M	N	220 SF	Other	Assumed	N/A	
Wall	Asbestos Cement Panel	m	N	100 SF	Other	Assumed	N/A	
Wall	Sheet Rock	M	N	0 SF	Serp	Sampled	10	011H00

Building No: 003 **Room H305** **Description Hallway/Stairs** **Drawing No: 4**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Flooring	Tile 9 In. & Floor Mastic	M	N	120 SF	Other	Assumed	N/A	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 16 of 22

SITE: 594 A. WARREN MCCLASKEY Address: 5241 J STREET, Sacramento 95819

Building No: 003 Room I302 Description Lounge Drawing No: 4

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	440 SF	Non ASB	Sampled	0	E2098
Flooring	Mastic	m	N	SF	Non ASB	Sampled	0	B3387
Flooring	Vinyl Sheet	m	N	440 SF	Non ASB	Sampled	0	B3387
Wall	Plaster	S	N	510 SF	Non ASB	Sampled	0	E2083

Building No: 003 Room K307 Description Kitchen Drawing No: 4

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	10	011H00
Flooring	Tile 9 In. & Floor Mastic	M	N	240 SF	Other	Assumed	N/A	
Kiln	Kiln Block	M	Y	SF	Non ASB	Sampled	0	E2095
Wall	Asbestos Cement Panel	m	N	150 SF	Other	Assumed	N/A	
Wall	Fire Rated Door	M	N	21 SF	Other	Assumed	N/A	

Building No: 003 Room M304 Description Mechanical Room Drawing No: 4

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Sheet Rock	M	N	0 SF	Serp	Sampled	10	011H00
Flooring	Tile 9 In. & Floor Mastic	m	N	15 SF	Other	Assumed	N/A	
Mechanical	Gasket	M	N	4 SF	Other	Assumed	N/A	
Wall	Sheet Rock	M	N	69 SF	Serp	Sampled	10	011H00

Building No: 003 Room M305 Description Mechanical Room Drawing No: 4

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	96 SF	Serp	Sampled	5	003H00
Ceiling	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	016H00
Ceiling	Sheet Rock	M	N	10 SF	Serp	Sampled	10	011H00
Flooring	Tile 9 In. & Floor Mastic	M	N	96 SF	Other	Assumed	N/A	
Wall	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	016H00
Wall	Sheet Rock	M	Y	60 SF	Serp	Sampled	10	011H00

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 17 of 22

SITE: 594		A. WARREN MCCLASKEY			Address: 5241 J STREET, Sacramento 95819					
Building No:	003	Room	N014	Description	Shop		Drawing No:	4		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Texture	S	N	1200	SF	Serp	Sampled	5	003H00	
Ceiling	Sheet Rock	M	N	0	SF	Non ASB	Sampled	0	016H01	
Flooring	Tile 9 In. & Floor Mastic	M	N	704	SF	Other	Assumed	N/A		
Misc.	Other	M	Y	0	SF	Serp	Sampled	75	T1968	
Wall	Asbestos Cement Panel	m	N	500	SF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0	SF	Non ASB	Sampled	0	016H01	
Wall	Sheet Rock	M	N	150	SF	Serp	Sampled	10	011H00	

Building No:	003	Room	N017	Description	Shop		Drawing No:	4		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Lay In	m	N	900	SF	Non ASB	Sampled	0	B1753	
Flooring	Tile 9 In. & Floor Mastic	M	N	1200	SF	Other	Assumed	N/A		
Mechanical	Flue	M	N	4	LF	Other	Assumed	N/A		
Wall	Acoustical Texture	S	N	820	SF	Serp	Sampled	5	003H00	
Wall	Asbestos Cement Panel	m	N	500	SF	Other	Assumed	N/A		
Wall	Sheet Rock	M	N	0	SF	Non ASB	Sampled	0	016H00	

Building No:	003	Room	O013	Description	Classroom		Drawing No:	4		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Tile, Lay In	M	N	0	SF	Non ASB	Sampled	0	006H00	
Ceiling	Fiberboard	m	N	900	SF	Non ASB	Sampled	0	B1750	
Flooring	Vinyl Sheet	M	N	810	SF	Non ASB	Sampled	0	E2091	
Wall	Plaster	S	N	590	SF	Non ASB	Sampled	0	E2083	

Building No:	003	Room	O015	Description	Classroom		Drawing No:	4		
Location	Homogeneous Material	Class	Friable	Material Size		Type of Asbestos	Sample Type	% Asbestos	Sample #	
Ceiling	Acoustical Texture	S	Y	1200	SF	Serp	Sampled	5	003H00	
Ceiling	Sheet Rock	M	Y	1200	SF	Non ASB	Sampled	0	016H01	
Flooring	Tile 9 In. & Floor Mastic	M	N	1200	SF	Other	Assumed	N/A		
Mechanical	Flue	M	N	8	SF	Other	Assumed	N/A		
Wall	Asbestos Cement Panel	m	N	500	SF	Other	Assumed	N/A		

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 594		A. WARREN MCCLASKEY			Address: 5241 J STREET, Sacramento 95819					
Building No:	003	Room	O016	Description	Classroom	Drawing No:	4			
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Acoustical Texture	S	N	1200 SF	Serp	Sampled	5	003H00		
Ceiling	Acoustical Tile, Lay In	m	N	900 SF	Non ASB	Sampled	0	B1753		
Flooring	Tile 9 In. & Floor Mastic	M	N	1200 SF	Other	Assumed	N/A			
Mechanical	Flue	M	N	4 LF	Other	Assumed	N/A			
Wall	Acoustical Texture	S	N	820 SF	Serp	Sampled	5	003H00		
Wall	Asbestos Cement Panel	m	N	500 SF	Other	Assumed	N/A			
Wall	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	016H00		

Building No:	003	Room	S017	Description	Storage	Drawing No:	4			
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Fiberboard	m	N	220 SF	Non ASB	Sampled	0	B1750		

Building No:	003	Room	S15A	Description	Storage	Drawing No:	4	No Suspect Materials Present		
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		

Building No:	003	Room	S15B	Description	Storage	Drawing No:	4	No Suspect Materials Present		
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		

Building No:	003	Room	S300	Description	Storage	Drawing No:	4			
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Plaster	S	N	24 SF	Non ASB	Sampled	0	E2098		
Wall	Plaster	S	N	110 SF	Non ASB	Sampled	0	E2083		

Building No:	003	Room	S302	Description	Storage	Drawing No:	4			
Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #		
Ceiling	Plaster	S	N	120 SF	Non ASB	Sampled	0	E2098		
Wall	Plaster	S	N	270 SF	Non ASB	Sampled	0	E2083		

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 19 of 22

SITE: 594 A. WARREN MCCLASKEY Address: 5241 J STREET, Sacramento 95819

Building No: 003 Room S307 Description Storage Drawing No: 4

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Texture	S	N	240 SF	Serp	Sampled	5	003H01
Ceiling	Acoustical Tile, Lay In	m	N	SF	Non ASB	Sampled	0	B1753
Ceiling	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	016H00
Flooring	Tile 9 In. & Floor Mastic	M	N	1200 SF	Other	Assumed	N/A	
Wall	Asbestos Cement Panel	m	N	150 SF	Other	Assumed	N/A	

Building No: 003 Room S308 Description Storage Drawing No: 4

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	016H00
Wall	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	016H01

Building No: 003 Room S309 Description Storage Drawing No: 4

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Wall	Acoustical Tile, Splined	M	N	184 SF	Non ASB	Sampled	0	E2081

Building No: 003 Room S310 Description Storage Drawing No: 4 No Suspect Materials Present

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
----------	----------------------	-------	---------	---------------	------------------	-------------	------------	----------

Building No: 003 Room T302 Description Toilet Drawing No: 4

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	110 SF	Non ASB	Sampled	0	E2098
Misc.	Electrical Fixtures	m	N	SF	Other	Assumed	N/A	
Wall	Plaster	S	N	250 SF	Non ASB	Sampled	0	E2083

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 594 **A. WARREN MCCLASKEY** **Address: 5241 J STREET, Sacramento 95819**

Building No: 003 **Room T303** **Description Toilet** **Drawing No: 4**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	42 SF	Non ASB	Sampled	0	E2098
Flooring	Mastic	m	N	SF	Non ASB	Sampled	0	B3366
Flooring	Vinyl Sheet	m	N	220 SF	Non ASB	Sampled	0	B3366
Wall	Plaster	S	N	160 SF	Non ASB	Sampled	0	E2083

Building No: 003 **Room T304** **Description Toilet** **Drawing No: 4**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Plaster	S	N	42 SF	Non ASB	Sampled	0	E2098
Flooring	Mastic	m	N	SF	Non ASB	Sampled	0	B3366
Flooring	Vinyl Sheet	m	N	220 SF	Non ASB	Sampled	0	B3366
Wall	Plaster	S	N	160 SF	Non ASB	Sampled	0	E2083

Building No: 003 **Room T305** **Description Toilet** **Drawing No: 4**

No Suspect Materials Present

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
----------	----------------------	-------	---------	---------------	------------------	-------------	------------	----------

Building No: 003 **Room T306** **Description Toilet** **Drawing No: 4**

No Suspect Materials Present

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
----------	----------------------	-------	---------	---------------	------------------	-------------	------------	----------

Building No: 003 **Room Z017** **Description Misc. Room** **Drawing No: 4**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Sheet Rock	M	N	120 SF	Serp	Sampled	10	011H00
Flooring	Tile 9 In. & Floor Mastic	M	N	220 SF	Other	Assumed	N/A	
Wall	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	016H00

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

SITE: 594 **A. WARREN MCCLASKEY** **Address: 5241 J STREET, Sacramento 95819**

Building No: 003 **Room ZA31** **Description Attic** **Drawing No: 5**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Attic	Debris	m	N	200 SF	Non ASB	Sampled	0	B1836
Ceiling	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	015B00
Mechanical	Flue	M	N	5 LF	Other	Assumed	N/A	

Building No: 003 **Room ZA32** **Description Attic** **Drawing No: 4**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Electrical Wiring	M	Y	15 SF	Other	Assumed	N/A	
Ceiling	Sheet Rock	M	N	0 SF	Non ASB	Sampled	0	015B00

Building No: 003 **Room ZC33** **Description Crawl Space** **Drawing No: 5**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Piping	Heat Hot Water Insulation	T	Y	250 LF	Other	Assumed	N/A	

Building No: 003 **Room ZEXT** **Description Exterior** **Drawing No: 4**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Exterior, Wall	Asbestos Cement Panel	m	N	3000 SF	Other	Assumed	N/A	

SACRAMENTO CITY UNIFIED SCHOOL DISTRICT - AHERA 3 YEAR SUSPECT MATERIAL REPORT

DATE PRINTED: 7/1/2011 1

Page 22 of 22

SITE: 594 **A. WARREN MCCLASKEY** **Address: 5241 J STREET, Sacramento 95819**

Building No: P01 **Room P0B1** **Description Classroom** **Drawing No: 4**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Tile, Lay In	M	N	960 SF	Non ASB	Sampled	0	018H00
Wall	Fire Rated Door	M	N	21 SF	Other	Assumed	N/A	

Building No: P01 **Room P0B2** **Description Classroom** **Drawing No: 4**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Tile, Lay In	M	N	960 SF	Non ASB	Sampled	0	018H00
Flooring	Tile 12 In.	M	N	960 SF	Non ASB	Sampled	0	P1538

Building No: P01 **Room P0B3** **Description Classroom** **Drawing No: 4**

Location	Homogeneous Material	Class	Friable	Material Size	Type of Asbestos	Sample Type	% Asbestos	Sample #
Ceiling	Acoustical Tile, Lay In	M	N	960 SF	Non ASB	Sampled	0	018H00
Flooring	Tile 12 In.	M	N	960 SF	Non ASB	Sampled	0	P1538